

SG PSB-OF-07183

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product Uninterruptible Powersupplies (UPS)

(Uninterruptible Power Supply)

Name and address of the applicant Vertiv Group Corporation

1050 Dearborn Drive Columbus OH 43085

USA

Name and address of the manufacturer Vertiv Group Corporation

1050 Dearborn Drive, Columbus OH 43085, USA

Name and address of the factory

Zhongshan Voltronic Power Electronics Limited

No.8 Shichong Road, Zhongshan Torch Hi-Tech Industrial Development Zone, 528437 Zhongshan, Guangdong, PEOPLE'S REPUBLIC OF CHINA

Ratings and principal characteristics Ratings:

For model GXE3-1000IRT2UXL: Input: 220-240VAC, 50/60Hz, 6A, 1Φ Output: 220/230/240VAC, 50/60Hz, 4.6A, 1Φ

Capacity: 1000VA/900W

Icc≤3kA

For model GXE3-EBC24VRT2U: Nominal Voltage: 24VDC Nominal Capacity: 18Ah

Protection Class: I

Degree of Protection: IP20

Model/type Ref. For UPS unit: GXE3-1000IRT2UXL;

For external battery cabinet: GXE3-EBC24VRT2U

Additional information (if necessary)

See Test Report for National Differences and Group Differences

A sample of the product was tested and found

to be in conformity with

IEC 62040-1:2017

IEC 62040-1:2017/AMD1:2021

as shown in the Test Report Ref. No. 211-21230300-000 which forms part of this certificate

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003651 0033 Rev. 00 Date, 2023-08-04

Ofla



PSB Singapore



SG PSB-OF-07183

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)



Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 003651 0033 Rev. 00

Date, 2023-08-04

Colia



(Bruce Zhang)